

## ARTICLE V. FUEL GAS CODE

### Sec. 18-91. Adoption of *International Fuel Gas Code* (2003); amendments.

The *International Fuel Gas Code* (2003), promulgated by the International Code Council, is adopted and incorporated in this article by reference as if fully set forth, except as it is amended by the following provisions of this section. Provisions of this article are in addition to the provisions of the *International Fuel Gas Code*. The following provisions coinciding with provisions of the *International Fuel Gas Code* supercede, or delete, when indicated, the corresponding provisions of the *International Fuel Gas Code*.

All references within the model codes to any building, electrical, gas, mechanical, plumbing, sewage disposal, elevator or energy conservation code shall be construed to be a reference to the respective building, electrical, gas, mechanical, plumbing, sewage disposal, elevator, energy conservation or existing building code specifically adopted by reference in articles II through XIV of this code.

**Chapter 1, Administration**, is deleted; except for Section 101.2, Scope, which is hereby adopted as amended. See article 1 of this chapter.

**101.2 Scope.** This code shall apply to the installation of fuel gas utilization equipment and related accessories and shall include installation, combustion and ventilation air and venting.

**101.2.1, 101.2.3, 101.2.4, 101.2.5** are adopted without amendment.

**101.2.2 Piping Systems.** See Article VII for fuel gas piping systems.

In **Section 202**, the following definitions have been revised:

**Flood hazard area.** See Code of Ordinances Chapter 28, Floodplain Management.

**301.6 Plumbing connections.** Potable water supply and building drainage system connections to appliances shall be in accordance with Article VII of this chapter.

**401 through 411, 414, 415** – Deleted. (See Article VII of this chapter for fuel gas piping installation requirements.)

See Article VII of this chapter for restrictions on the installation of liquefied petroleum (LP) gas piping systems and utilization equipment.

**627.2 Independent piping.** Gas piping serving heating equipment shall be permitted to also serve cooling equipment where such heating and cooling equipment cannot be operated simultaneously. (See Article VII of this chapter.)

**Secs. 631, 632** (Boilers) – Deleted.

(Ord. No. 010783, 8-23-01; Ord. No. 040477, 8-12-04)

**Secs. 18-92—18-107. Reserved.**